

TEST REPORT **35323**

Date received: 24-02-03

Date of issue: 06-03-03

Spett. TERNO SCORREVOLI S.N.C.
VIA RAVENNA , 4
20039 VAREDO (MI)
ITALY

Sample name: ART. 60/S/P/NR200CON GUARN. C/PROFILO 200 CM C/SQUAD CON BINARIO DA 2 METRI
ART. 1080 PORTATA 60 KG

Performance Characteristics:

Defects before test:


None.



Report consists of 1 attached sheet.

Head of Department

A handwritten signature in black ink, appearing to be 'M. M.', written over the text 'Head of Department'.



Chief Executive
Dott. Ing. Angelo Speranza

A large, stylized handwritten signature in blue ink, written over the text 'Chief Executive Dott. Ing. Angelo Speranza'.

Sample name is declared by the company who asked for the test. This report relates to the samples submitted for the test and no others. Additions, deletions or alterations are not permitted. This test report must always be reproduced in its entirety.

TEST REPORT

35323 / 1

Date received: 24-02-03
Date of test: 26-02-03
Date of issue: 06-03-03



Spett. TERNO SCORREVOLI S.N.C.
VIA RAVENNA, 4
20039 VAREDO (MI)
ITALY

Sample name: ART. 60/S/P/NR200CON GUARN. C/PROFILO 200 CM C/SQUAD CON BINARIO DA 2 METRI ART. 1080 PORTATA 60 KG

Sliding Doors - Durability test PTP 76/97

Type of guide fittings : plastic material wheels runner
Dimension: 30 x 30 x 2000 mm thickness 2
Frequency: 6 cycles/min

Test method

The test has been carried out moving the guide for its entire travel distance for the number of cycles shown in the table below.

A cile consist of a complete travel forward an backward.

As request by the costumer, a plywood panel has been fixed to the guide.

Panel dimensions: 1120 x 30 x 590 mm

Weight: 7 kg

Added weight: 53 kg

Test result

Cycles	Weight kg	Note
30000	60	No defects

Head of Department



Chief Executive
Dott. Ing. Angelo Speranza